



Addendum No. 2

ITB No. 16-29 Raw Water Pumps #1 and #3 Repairs

October 3, 2016

ITB #16-29 is hereby amended as follows:

1. Below are request for clarifications received and corresponding answers:

- A. Question: Can you clarify the following via addendum? During the PRE-BID meeting the paint coating system was discussed. It was suggested that the pumps be coated equal to the original coating as opposed to industrial grade enamel with no sand blasting requirement.

Please confirm the following:

- Inside and Outside of pump suction bell, two bowls and discharge adapter shall be sandblasted to SSPC-10 Near White Metal blast and primed and finish painted to match page 1 of 5 of the original order, as included in addendum #1 detail sheets.
- Inside and Outside of pump Flanged Column Assemblies shall be sandblasted to SSPC-10 Near White Metal blast and primed and finish painted to match page 2 of 5 of the original order, as included in addendum #1 detail sheets.
- Inside of pump Discharge Head and Stuffing Box shall be sandblasted to SSPC-10 Near White Metal blast and primed and finish painted to match page 3 and 4 of 5 of the original order, as included in addendum #1 detail sheets.
- Clarify if the outside of the existing discharge head located in the pump room can be etched and painted with Industrial Grade Enamel or if it also must be commercial blasted and painted per page 5 of 5 with a three coat paint system.

It should be noted that the TENEMEC paint system applied to the pump and wetted parts must cure seven days before IMMERSION service.

Answer: If each bidder uses the O & M, they can sandblast the entire pump, use the coatings recommended by the manufacturer, and reinstall the pumps as they are removed. Bidders who attended the mandatory pre-bid conference were given the opportunity to review the O & M and were given copies of applicable pages from the O & M.

- B. Question: In regards to page 5 of 24 of the solicitation can you confirm our scope of work will not require Insurance for:



- Contractors Pollution Liability
- Environmental Impairment Liability

Answer: The scope of work will not require the Contractors Pollution Liability and Environmental Impairment Liability.

- C. **Question:** It was generally acknowledged by several bidders that the existing Pump Impellers cannot be altered with a performance guarantee and therefore we will not be able to offer pricing options 2 and 3 of the Bid Summary. Only the manufacturer of the impeller can make alterations that do not affect performance.

Answer: The specs list (3) options. Each bidder can choose any option. This is stated as some company's do not want to refurbish impellers and bowls, but would rather replace with new. Some company's might wish to consult the manufacturer for further information about modifications.

2. Below are questions received and corresponding answers:

- A. **Question:** With regards to the pump strainer, is there any type of anti-vortex device installed at the pump base?

Answer: The Pump can have vertical veins in it that deal with the Vortex. There should not be anything attached to the strainer.

- B. **Question:** During the pre-quote meeting it was mentioned that pump No.103 line shafts are worn. Should we include replacing the line and bowl shafts in the bid summary?

Answer: Add pricing to include any wear item that may need to be replaced (i.e. bushings, shafts, bolts). Listing as line items would be helpful as there is no positive way to check this until the pump is pulled and internal parts are inspected. See NOTE at the bottom of page 12 of the ITB. Bid Form has been revised and is attached to this Addendum No. 2. Bidders must use the revised Bid Form in lieu of the one currently in the ITB.

- C. **Question:** What hours will the site be available for our crews to work daily?

Answer: The site will be available Monday through Friday, 8:00 a.m. to 5:00 p.m.

- D. **Question:** Will there be a Rockdale County employee at the site during working hours?

Board of Commissioners
Richard A. Oden, Chairman
Oz Nesbitt, Sr., Commissioner
Dr. Doreen Williams, Commissioner



Department of Finance
Telephone: 770-278-7555
Facsimile: 770-278-8910

Answer: A county employee will be on site most of the time (depending on problems that arise), and contact information will be given to them just in case.

E. **Question:** Will the site be available during the weekend if necessary?

Answer: Weekends will not be available for work, due to our work schedule. Pulling the pump should not take but a day and installation about a day.

3. All other conditions remain in full force and effect.
4. If a proposal has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the proposal price, the new price and/or changes will be inserted below:

5. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on Page 13, Part II of the revised Bid Form.

Tina Malone

Tina Malone, CPPB CPPO
Procurement Officer
Department of Finance, Purchasing Division

Rev BID FORM – ITB No. 16-29

Instructions: Complete all THREE parts of this bid form.

PART I: Bid Summary

Complete the information below. If you wish to submit more than one brand, make a photocopy of this Bid Form.

1.	Complete removal, repair, reinstallation, and start up (including motor repairs) NOT-TO-EXCEED (NTE)	LUMP SUM	\$
	Option 1 - Standard refurbish of pump	LUMP SUM	\$
	Option 2 - Changes in bowl area to handle more solids, making sure to stay within the original pump curve	LUMP SUM	\$
	Option 3 – Changing bowl to one that can handle solids and pump dirty water making sure to stay within original pump curve	LUMP SUM	\$
	OTHER -		\$
	Contingency (10% of Subtotal)		\$
	TOTAL		\$
	Number of days for completion from Notice to Proceed (NTP):		_____ days

PART II: Addenda Acknowledgements (if applicable)

Each vendor is responsible for determining that all addenda issued by the Rockdale County Finance Department – Purchasing Division have been received before submitting a bid.

Addenda	Date Vendor Received	Initials
"1"		
"2"		
"3"		
"4"		
"5"		
"6"		

PART III: Vendor Information:

Vendor Name	
Address	
Telephone	
E-Mail	
Representative (print name)	
Signature of Representative	
Date Submitted	